



4GC0357520110815

2011/08/15

4GC03575

TIRE DISCOUNTERS-SUNBURY RD



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 15, 2011

David Wilson
Tire Discounters Inc.
7525 Wooster Pike
Cincinnati, OH 45227

**Re: Storm Water Inspection at Tire Discounters – Sunbury Road / Delaware County
Permit Number: 4GC03575*AG**

Dear Mr. Wilson:

This letter is written in follow-up to a construction storm water inspection by Kelsey Heyob and Donny King of the Ohio EPA, conducted at Tire Discounters located at 795 Sunbury Road in Delaware, Ohio on August 1, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- The apparent sediment pond shown in Figure 1 must eventually include an outlet structure modified for sediment control.

Olentangy Watershed Permit:

- This site was granted authorization under a statewide permit; however, given the project lies within the Olentangy Watershed, coverage under the General Storm Water Permit for Olentangy Watershed must be authorized. Please submit a new Notice of Intent and Storm Water Pollution Prevention Plan for approval. Once the Olentangy Watershed permit is granted, a Notice of Termination is required for the current statewide permit.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,


FOR HK
Harry Kalipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Matt Weber, Assistant City Engineer, Delaware, OH

HK/nsm Tire Discounters 8-3-2011
Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov





Figure 1

