



\*4GC0343620110811\*

2011/08/11

4GC03436

OHIO SOIL RECYCLING LLC



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 11, 2011

Chris Elliott  
Ohio Soil Recycling, LLC  
2101 Integrity Drive  
Columbus, OH 43209

**Re: Construction Storm Water Inspection at Ohio Soil Recycling  
Franklin County  
Permit Number: 4GC03436\*AG**

Dear Mr. Elliott:

This letter is written regarding a storm water inspection conducted by Greg Mann and Daelann Farnlacher of the Ohio EPA at Ohio Soil Recycling located at 2101 Integrity Drive Columbus, Ohio on August 3, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Our staff noted during the investigation that new sediment ponds are required for Phase 2 of this site. Sediment Pond #1 has been installed. Please install Sediment Pond #2 in accordance with the new Storm Water Pollution Prevention Plan.
- Please ensure the site is graded for successful drainage of storm water to the basins intended for sediment control.
- It is required that temporary skimmers be incorporated in both sediment ponds.
- During the investigation, our staff observed the lack of posi-shell protection on some of the wind rows. Please take corrective measures to minimize the erosion from these areas.

Chris Elliott  
Ohio Soil Recycling, LLC  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO