



4GC0339420110811

2011/08/11

4GC03394

SPEEDWAY SUPERAMERICA LLC #5238



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 10, 2011

Scott Weber
ATCS Inc.
200 Lau Parkway
Clayton, OH 45315

**Re: Storm Water Inspection at Speedway Super America LLC #5238
Franklin County
Permit Number: 4GC03394*AG**

Dear Mr. Weber:

This letter is written in follow-up to a construction storm water inspection by Kelsey Heyob and Donny King of the Ohio EPA, conducted at the Speedway #5238 located at 955 South Galloway Road in Columbus, Ohio on August 1, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit associated with construction activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls

- The dandy bag covering the storm drain on the west side of the site must be maintained at this time to ensure a proper functioning condition (See Figure 1).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. It was noted that the entrance to the gas station was properly protected, but there were exposed areas behind the gas station where sediment was being tracked onto the road and clogging the dandy bag (See Figure 1 and 2).


Notice of Termination

- It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction requirements are met.

Scott Weber
ATCS Inc.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Speedway 8-3-2011



Figure 1: Dandy bag on west side of site



Figure 2

