



4GCO000420110810

2011/08/10

4GCO0004

RICHWOOD BANK - DELAWARE/VALLEY RUN DRIVE



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 10, 2011

Chad Hoffman
Page Engineering INC
PO Box 394
112 East Fifth Street
Marysville, OH 43040

**Re: Construction Storm Water Inspection at Richwood Bank-Delaware/ Valley Run Drive /
Delaware County
Permit Number: 4GCO00045*AG**

Dear Mr. Hoffman:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher, Don King and Lauren Burns of the Ohio EPA at Richwood Bank-Delaware/ Valley Run Drive located at 1512 West Williams Street Delaware, Ohio on July 22, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection our staff, was informed by the contractor of the installation of a sediment pond. Please be advised that the sediment pond must comply with all regulations and guidelines listed in the General Permit.
- Installation of silt fence is required around the storm drain located on the south end of the site. Please ensure that the installation and maintenance of the silt fence complies with General Permit (see Figure 1).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Richwood Bank Delaware 7-22-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov






Figure 1

