



\*4GC0357120110810\*

2011/08/10

4GC03571

GURU NANAK RELIGIOUS SOCIETY OF CENTRAL OHIO



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 10, 2011

Satpal Bir  
Guru Nanak Religious Society of Central Ohio  
3745 Business Park Drive  
Columbus, OH 43204

**Re: Storm Water Inspection at Guru Nanak Religious Society of Central Ohio / Franklin  
County  
Permit Number: 4GC03571\*AG**

Dear Mr. Bir:

This letter is written in follow up to a construction storm water inspection by Kelsey Heyob and Donny King of the Ohio EPA conducted at the Guru Nanak Religious Society of Central Ohio located at 3745 Business Park Drive in Columbus, Ohio on August 1, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls**

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (email preferred) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Guru Nanak 8-1-2011

