



4GC0299620110810

2011/08/10

4GC02996

HILLIARD ROM ROAD - PHASE II



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 10, 2011

Doug Tomsic
Columbia Gas of Ohio/ NiSource Co.
3222 West Central Avenue
Toledo, OH 43606

**Re: Storm Water Inspection at Hilliard Rome Road – Phase II / Franklin County
Permit Number: 4GC02996*AG**

Dear Mr. Tomsic:

This letter is written in follow-up to a construction storm water inspection I conducted at Hilliard Rome Road – Phase II located in Hilliard, Ohio on July 29, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- Currently, excavation is proceeding in a manner where all storm water is contained. Any pumping of accumulated water within the project must be conducted in a manner which will not result in turbid discharges to waters of the state.
- Once off-site storm water flow is established, additional sediment controls, such as inlet protections, are required.


Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Doug Tomsic
Columbia Gas of Ohio/ NiSource Co.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (email preferred) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Hilliard Rome Road Phase II 7-29-2011