



4GCD000520110809

2011/08/09

4GCD0005

NEW PLAIN CITY ELEMENTARY SCHOOL



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 9, 2011

Dr. Doug Carpenter
Jonathon Alder School District
9200 US Route 42 South
Plain City, OH 43064

**Re: Storm Water Inspection at New Plain City Elementary School
Madison County
Permit Number: 4GCD00058*AG**

Dear Dr. Carpenter:

This letter is written in follow up to a construction storm water inspection by Kelsey Heyob and Lauren Burns of the Ohio EPA, conducted at New Plain City Elementary located adjacent to Plain City-Georgesville Road in Plain City, Ohio on July 26, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following was noted:

Sediment and Erosion Controls:

- All barren areas are directed to the pond as intended by the permit. However, the infiltration basins will require sediment removal prior to completion of the site; as the accumulated sediment has impacted the infiltration media and the intended function.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm New Plain City Elementary

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

