



4GCO000320110808

2011/08/08

4GCO0003

DELAWARE AREA CAREER CENTER



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 9, 2011

Christopher Bell
Delaware Area Career Center
4565 Columbus Pike
Delaware, OH 43015

**Re: Notice of Termination Inspection at Delaware Area Career Center
Delaware County
Permit Number: 4GCO00039*AG**

Dear Mr. Bell:

This letter is written in follow-up to a construction storm water inspection by Daelann Farnlacher, Don King, and Lauren Burns of the Ohio EPA we conducted at Delaware Area Career Center located at 4564 Columbus Pike (US Route 23) Delaware, Ohio on July 22, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity is near completion. A Notice of Termination will be required provided the post construction requirements are met. In addition the site must be stabilized with vegetation sufficient to control erosion, measured by a minimum vegetative density of 70 percent.

Please address the following:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Christopher Bell
Delaware Area Career Center

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Delaware Area Career Center 7-22-11