



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 3, 2011 -

Chuck Evans
Schottenstein Real Estate Group
2 Easton Oval # 510
Columbus, OH 43219

**Re: Construction Storm Water Inspection at Hilliard Meadows / Franklin County
Permit Number: 4GCD00075*AG**

Dear Mr. Evans:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Greg Mann of the Ohio EPA at Hilliard Meadows located at Roberts Road and Darby Creek Road Hilliard, Ohio on July 19, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It was noted that corrective measures were taken associated with the dewatering activities observed during our last inspection.
- During the inspection, two storm drains were noted that require appropriate inlet protection (see Figures 1 and 2).
- Linear silt fence along the designated wetland must be repaired.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at: harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Hilliard Meadows 7-19-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov






Figure 1: Inlet protection required



Figure 2: Inlet protection required

