



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 2, 2011

Greg Essig
Dublin Building Systems
6233 Avery Road
PO Box 370
Dublin, OH 43017

**Re: Construction Storm Water Inspection at Carr Supply / Franklin County
Permit Number: 4GC03465*AG**

Dear Mr. Essig:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Greg Mann of the Ohio EPA at Carr Supply located at 1415 Old Leonard Avenue Columbus, Ohio on July 18, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The storm drain noted in Figure 1 must have appropriate inlet protection in order to minimize the discharge of sediment into waters of the state.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Greg Essig
Dublin Building Systems
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Carr Supply 7-18-2011



City of
All
Photo by
7
uncovered storm drain

Figure 1: Uncovered storm drain

