



4GCO000520110728

2011/07/28

4GCO0005

TURKEY HILL MINIT MARKET #707



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 28, 2011

Tim Richards
TH Midwest Incorporated
2600 Corporate Exchange Boulevard
Suite 170
Columbus, OH 43231

**Re: Construction Storm Water Inspection at Turkey Hill Minit Market #770
Delaware County
Permit Number: 4GCO00053 *AG**

Dear Mr. Richards:

This letter is written regarding a storm water inspection I conducted at Turkey Hill Minit Market #770 located at 2740 Stratford Road Delaware Ohio on July 12, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Based on my observations, the majority of the runoff associated with this site is currently contained within current excavation.
- The Storm Water Pollution Prevention Plan requires the installation of a temporary sediment impoundment. Corrective measures must include the installation of this impoundment within seven days of receipt of this letter.
- *Perimeter silt fence was installed and appears to be functioning as intended.*

Barren Areas: 21 Day Rule:

Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Tim Richards
TH Midwest Incorporated
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Turkey Hill Minit #170 7-12