



\*4GCO000420110728\*

2011/07/28

4GCO0004

RICHWOOD BANK - DELAWARE/VALLEY RUN DRIVE



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 28, 2011

Chad Hoffman  
Page Engineering  
PO Box 394  
112 East Fifth Street  
Marysville OH 43040

**Re: Construction Storm Water Inspection at Richwood Bank / Delaware County  
Permit Number: 4GCO00045 \*AG**

Dear Mr. Hoffman:

This letter is written regarding a storm water inspection I conducted at Richwood Bank located at 1512 West Williams Street, Delaware Ohio on July 12, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Current perimeter silt fence is inadequate to address the minimum requirements of the general permit. Specifically as the storm water exits the site to the existing basin.
- Corrective measures are expected to modify the current basin to accurately address sediment control for this site.
- Please ensure all silt fence is properly installed and properly maintained in preparation for my next inspection during the week of Monday July 25, 2011.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

