



\*4GC0346020110726\*

2011/07/26

4GC03460

KROGER FUEL CENTER N-817



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 26, 2011

Alan McLoughlin  
The Kroger Company  
4111 Executive Parkway  
Westerville, OH 43081

**Re: Construction Storm Water Inspection at Kroger Fuel Center N-817 / Franklin County  
Permit Number: 4GC03460\*AG**

Dear Mr. McLoughlin:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Don King of the Ohio EPA at Kroger Fuel Center N-817 located at 7200 Hospital Drive Dublin, Ohio on July 8, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities.

**Sediment and Erosion Control:**

- Please submit an electronic copy of the Storm Water Pollution Prevention Plan for review.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCOA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Kroger Fuel Center N-817 7-8-11

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

