



\*4GC0346620110726\*

2011/07/26

4GC03466

MCDONALDS RESTAURANT



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 26, 2011

David Warren  
McDonalds Corporation  
2 Easton Oval, Suite 200  
Columbus, OH 43219

**Re: Construction Storm Water Inspection at McDonalds Restaurant / Franklin County  
Permit Number: 4GC03466 \*AG**

Dear Mr. Warren:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Kelsey Heyob of the Ohio EPA at McDonalds Restaurant located at 298 South Hamilton Road Gahanna, Ohio on July 5, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Our staff noted an uncovered storm sewer drain which requires appropriate inlet protection. (See Figure 1).
- Silt fence must be installed around the entire perimeter of the site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office


Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm McDonalds Restaurant 7-5-2011

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)






Figure 1: Uncovered storm drain

