



4GC0347520110726

2011/07/26

4GC03475

BJS RESTAURANT & BREWHOUSE



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 26, 2011

Jeffrey Harris
Restaurant Specialties Inc.
999 Polaris Parkway Suite 111
Columbus, OH 43240

**Re: Construction Storm Water Inspection at BJ's Restaurant & Brewhouse
Franklin County
Permit Number: 4GC03475*AG**

Dear Mr. Harris:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Don King of the Ohio EPA at BJ's Restaurant & Brewhouse located at 5141 Tuttle Crossing Boulevard – Blazer Parkway Dublin, Ohio on July 8, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection, our staff noted two storm sewer drains that require appropriate inlet protection (See Figures 1 and 2).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm BJ's Restaurant Brewhouse 7-8-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov





Figure 2: Storm drain at entrance to site




Figure 1: Storm drain next to Tuttle Mall parking lot

