



4GC0343120110718

2011/07/18

4GC03431

NORTH UNION HIGH SCHOOL TRACK



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 21, 2011

Scott Maruniak
North Union Local School District
12920 State Route 739
Richwood, OH 43344

**Re: Construction Storm Water Inspection at North Union High School Track /
Union County
Permit Number: 4GC03431*AG**

Dear Mr. Maruniak:

This letter is written regarding the storm water inspection conducted by Lindsey Boaz and Lauren Burns of the Ohio EPA at North Union High School Track located at 401 North Franklin Street Richwood, Ohio on June 28, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Control:

- The storm inlet catch basin noted in Figure 1 will require protection to minimize soil loss from the site.
- The perimeter silt fence will require maintenance.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Scott Maruniak
North Union Local School District
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at: harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO



Figure 1: Storm inlet requiring protection from sediment erosion.

