



4GCD000720110721

2011/07/21

4GCD0007

ANDERSON MEADOWS



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 20, 2011

Paul Coppel
Schottenstein Homes Inc.
140 Mill Street, Suite A
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Anderson Meadows / Franklin County
Permit Number: 4GCD00079 *AG**

Dear Mr. Coppel:

This letter is written regarding a storm water inspection I conducted at Anderson Meadows located at 1500 East Intersection Alton-Darby Road & Roberts Road Hilliard, Ohio on July 6, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection, I noted the large centralized sediment basin excavated at the site.
- An outlet structure, modified to address sediment control, must be installed.
- Please ensure grading is implemented to route all barren areas to the impoundment intended for sediment control, prior to the storm installation.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Anderson Meadows 7-6-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

