



4GCO000320110720

2011/07/20

4GCO0003

VILLAGE ACADEMY PRE-SCHOOL



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 20, 2011

Suzie Lasley
Village Academy Schools
248 South Liberty Street
Powell, OH 43065

**Re: Construction Storm Water Inspection at Village Academy Pre-School / Delaware County
Permit Number: 4GCO00038 *AG**

Dear Ms. Lasley:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher, Don King, and Greg Mann of the Ohio EPA at Village Academy Pre-School located at 216 South Liberty Street, Powell, Ohio on June 30, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Our staff noted failed silt fence, shown in Figure 1, which requires maintenance at this time.
- Be aware that all sediment impoundments will require cleaning once they have exceeded 50 percent of their capacity. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Village Academy Pre-School 6-30-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov





Village Academy Pre-School
Ontonagon River Watershed
Photo By: Daelana Farnbacher
6/30/11
Failed Silt Fence

Figure 1: Failed silt fence

