



4GC0287820110720

2011/07/20

4GC02878

HOLIDAY INN PRIVATE ACCESS RD



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 20, 2011

Nitin Patel
Badriushal LLC
600 Enterprise Drive
Lewis Center, OH 43147

**Re: Construction Storm Water Inspection at Holiday Inn Private Access Road
Delaware County
Permit Number: 4GC02878*AG**

Dear Mr. Patel:

This letter is written regarding a storm water inspection I conducted at 2010 Polaris Parkway, Columbus Ohio on June 23, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please ensure the centralized sediment basin is maintained and functioning properly. During my inspection the temporary riser appears to be dislodged and not properly minimizing sediment discharge to waters of the state.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Holiday Inn Express Patel July 1, 2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

