



\*4GC0323520110720\*

2011/07/20

4GC03235

WORTHINGTON-GALENA RD & WORTHINGTON RD  
IMPROVEMENT



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 20, 2011

Jeff Kessler  
City of Westerville  
64 East Walnut Street  
Westerville, OH 43081

**Re: Construction Storm Water Inspection at Worthington Galena Road Improvement  
Franklin County  
Permit Number: 4GC03235\*AG**

Dear Mr. Kessler:

This letter is written regarding a storm water inspection I conducted at Worthington Galena Road on June 23, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities; this applies to areas on the northern end of the project.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Worthington Galena Road Improvement 6-23-2011

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

