



\*4GC0354720110718\*

2011/07/18

4GC03547

REYNOLDSBURG HIGH SCHOOL



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 18, 2011

Ron Strussion  
Reynoldsburg Public Schools  
7244 East Main Street  
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Reynoldsburg High School / Franklin County  
Permit Number: 4GC03547\*AG**

Dear Mr. Strussion:

This letter is written regarding a storm water inspection conducted by Greg Mann and Daelann Farnlacher of the Ohio EPA at Reynoldsburg High School located at 6699 East Livingston Avenue Reynoldsburg Ohio, on June 27, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Our staff noted unprotected storm water inlets on the east side of the complex. Please use proper inlet barriers to correct this issue to minimize sediment loss from the site (see Figure 1).
- During the inspection our staff was unable to determine the intended function of Sediment Barriers in Figure 2. Please advise in your response.
- The concrete washout area appears close to designed capacity. The wash out pit must be maintained.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Reynoldsburg High School 6-27-2011

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)






Figure 1



Figure 2

1950-1951

1950-1951




Figure 1




Figure 2

