



4GC0331420110718

2011/07/18

4GC03314

OLDE ORCHARD ELEMENTARY SCHOOL



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 28, 2011

Alex Trevino
Gutridge Plumbing Inc.
889 East 17th Avenue
Columbus, OH 43211

**Re: Construction Storm Water Inspection at Olde Orchard Elementary School
Franklin County
Permit Number: 4GC03314*AG**

Dear Mr. Trevino:

This letter is written regarding a storm water inspection conducted by Greg Mann and Daelann Farnlacher of the Ohio EPA at Olde Orchard Elementary School located at 800 McNaughten Road Columbus, Ohio on June 27, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Our staff observed an area of concrete disposal that lacked proper containment (Figure 1). If future onsite disposal is required, containment measures such as a pit impoundment is expected.
- The sediment and erosion controls, aside from the concrete disposal area, are currently functioning properly. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office


Enclosure

c: Jeff Bohne, Water Quality Supervisor DSW/CDO

HK/nsm Olde Orchard Elementary School 6-27-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov






Figure 1

