



\*4GC0033120110712\*

2011/07/12

4GC00331

WAGNALLS RUN PH 3, 4 & 5



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 12, 2011

Gene Pirko  
Westport Homes of Ohio  
507 Executive Campus Drive  
Suite #100  
Westerville, OH 43082

**Re: Wagnalls Run / Fairfield County**

Dear Mr. Pirko:

This letter is written regarding the storm water inspection I conducted, on June 27, 2011, of the construction activities at Wagnall's Run located near the intersection of S.R. 674 and Winchester Southern Road. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. There was no active construction taking place at the time of my inspection. Based on my site observations of the site and the conditions of the Storm Water Permit, the following items were noted.

**Sediment and Erosion Controls:**

- The site was stabilized and there were no barren areas.
- The concrete wash-out pit is full and needs to be maintained. It is recommended to construct another concrete wash pit.

If you have any questions regarding the contents of this letter, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne Water Quality Supervisor, DSW/CDO

GS/nm Wagnall's Run, June 27, 2011

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov

