



4GC0351820110711

2011/07/11

4GC03518

GLENROSS PARK



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 11, 2011

Matthew B. Weber
1 S. Sandusky Street
Delaware OH 43015

Re: **Construction Storm Water Inspection at Glenross Park / Delaware County**
Permit Number: 4GC03518*AG

Dear Mr. Weber:

This letter is written regarding a storm water inspection conducted by Greg Mann and Daelann Farnlacher of the Ohio EPA at Glenross Park located at 1800 Cheshire Road in Delaware, Ohio on June 22, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Our staff observed the silt fence was down on the west side of the site and storm water runoff was draining directly into the storm drain. This is a direct violation of the general permit and must be repaired/maintained within three days of receiving this letter. (see Figure 1)
- It was noted that inlet protections were not installed, please ensure proper inlet protection measures are installed or demonstrate an approvable alternative. (see Figure 2)
- It was noted that the entrance of the site was interfering with proper barrier controls. Please provide a stabilized entrance to the site (see Figure 3).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosures

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HKI/nsm Glenross Park 6-22-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov







Figure 2



Figure 1






Figure 3

