



4GC0340020110711

2011/07/11

4GC03400

NEW BLOOM CARROLL MIDDLE SCHOOL



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 11, 2011

Roger Mace
Bloom Carroll Local School District
5240 Plum Road NW
Carroll, OH 43112

Re: Bloom Carroll Middle School / Fairfield County

Dear Mr. Mace:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Bloom Carroll Middle School project located along Beaver Street. The inspection was conducted on June 24, 2011. The reason of the inspection was a follow-up to a previous storm water inspection. During the inspection, the following items were noted:

- The area in the front of the school had silt fence installed on the downslope of the site
- Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

As soon as possible, but no later than 30 days, install a riser on the sediment basin. Sediment impoundments must be utilized for areas of concentrated flow and must be sized with a sediment storage volume of 67 cubic yards per acre of drainage (not disturbance). These sediment impoundments will require cleaning once they have exceeded 50 percent of their capacity. The sediment impoundments appear to have exceeded their 50 percent capacity.

There is a small area in the rear of the school, near the gray modular building that needs to have erosion controls installed, i.e., silt fence. Please see attached pictures.

There is a small area in the rear of the school that has sediment discharging to the driveway. Please maintain erosion controls to prevent sediment run-off. Please see attached pictures.

Roger Mace
Bloom Carroll Local School District
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

*Gregory L. Sanders
For*

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Bloom Carroll HS, June 24, 2011

Bloom Carroll MS
Install erosion controls
Walnut Creek Watershed
June 24, 2011
Photo by: Greg Sanders



