



4GC0343220110711

2011/07/11

4GC03432

4288 MOUNTS RD



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 11, 2011

William Miller
4288 Mounts Road
Alexandria, OH 43001

**Re: Construction Storm Water Inspection at 4288 Mounts Road / Licking County
Permit Number: 4GC03432*AG**

Dear Mr. Miller:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Greg Mann of the Ohio EPA at 4288 Mounts Road, Alexandria, Ohio 43001 on June 24, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection, our staff noted that a new modified outlet structure for sediment control must be installed. A skimmer is recommended for increased efficiency.
- Please continue to monitor vegetation to ensure a successful vegetation cover to control erosion, measured by a minimum vegetation density of 70 percent.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor

HK/nsm 4288 Mount Road

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

