



State of Ohio Environmental Protection Agency

Southwest District

401 East Fifth Street
Dayton, Ohio 45402-2911TELE: (937)285-6357 FAX: (937)285-6249
www.epa.state.oh.usTed Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

September 4, 2007

RE: CLARK COUNTY
BROOKSIDE VILLAGE MHP
COMMUNITY WATER SYSTEM
PWS ID # 1200112Brookside Village MHP
1962 Mahar Road
South Vienna, Ohio 45369

Subject: I. Additional Total Coliform Samples Required

II. Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform BacteriaWe received the following total coliform sample results from your public water system.
The bacteriological analysis is as follows:

Sample Date	Sample Location	Total Coliform	E. Coli	Sample Number	Lab Cert Number
08/30/07	Lot 118	Positive	Negative	12182	600
08/31/07	Park Office	Positive	Negative	18184	600
08/31/07	Lot 113	Positive	Negative	12185	600
8/31/07	Lot 73	Positive	Negative	18186	600

I. Actions required as a result of the above sample result:

Step 1

Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:

1. mail or other direct delivery to each customer receiving a bill and to other service connections; and
2. if necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system.

The language in italics on the attached public notice is mandatory and must be included as written.

Brookside Village MHP
September 4, 2007
Page 2

Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Southwest District Office of the Ohio EPA.

Please note the 4 required repeat samples were collected on August 31, 2007. This resulted an MCL exceedance for total coliform bacteria for August, 2007.

If you have any questions, please contact me at (937) 285-6114.

Sincerely,



David R. Secor
Compliance Coordinator
Division of Drinking and Ground Waters

Enclosures

cc: Toni Buchanan, DDAGW, CO
Clark County Health Department

DRS\bp

DRINKING WATER NOTICE

Tests showed coliform bacteria in Brookside Village MHP water

We routinely monitor for the presence of drinking water contaminants. We took Five (5) samples for coliform bacteria during August 2007. Four (4) of those samples showed the presence of coliform bacteria. No more than one (1) sample per month may show the presence of coliform bacteria during a month.

What should I do?

- **You do not need to boil your water or take other corrective actions.** However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.
- Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution systems.
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*

Fecal coliform or *E. coli*, which are bacteria of greater concern, were not detected in the follow-up testing.

What is being done?

We are still detecting coliform bacteria. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____ or _____.
name of contact phone number mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWS ID# 1200112 Date distributed: _____

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR COMMUNITY
PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS**

The owner or operator of a community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use the following method to reach all persons served by the public water system:</p> <p>Public notice issued by mail or other direct delivery to each customer receiving a bill and to other service connections to which water is delivered by the public water system</p>	<p>Describe actual methods used to notify public of the violation:</p> <p>A. Date of mailing/delivery</p> <p>-----</p>
<p>If the above method does not reach all persons served, also use any other method reasonably calculated to reach other persons regularly served by the public water system (e.g. publication in a local newspaper, delivery of multiple copies for distribution by customers that provide their drinking water to others, posting in public places served by the system or on the Internet, or delivery to community organizations). If the notice is posted, it shall remain in place as long as the violation exists, but in no case less than 7 days.</p>	<p>A. Method(s)</p> <p>-----</p> <p>-----</p> <p>-----</p> <p>B. Date(s)</p> <p>-----</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

- A public notice as shown on the other side of this sheet was issued without changes.
- A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Official Date

Brookside Village MHP
NAME OF PUBLIC WATER SYSTEM

Printed Name and Title of Responsible Official

PWSID NUMBER: 1200112

COUNTY NAME: Clark

<p>For OEPA use only</p> <p>Date PN Received: _____</p> <p>PN acceptable: PN not acceptable:</p>	<p>VIOLATION TYPE: <u>22</u></p> <p>MONITORING PERIOD <u>August 2007</u></p>
--	--