OH3100112085508

State of Ohio Environmental Protection Agency

Southwest District

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937)285-6357 FAX: (937)285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 1, 2007

Re: HAMILTON County
RED WOOD MOBILE HOME PARK
COMMUNITY Water System
PWS ID# OH3100112

Red Wood Mobile Home Park
10169 Harrison Avenue
Harrison, Ohio 45030-9738

Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	**Within 30 days** issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: 1. Mail or other direct delivery to each customer receiving a bill and to other service connections; and 2. If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system. The language in italics on the attached public notice is mandatory and must be included as written.
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Southwest District Office of the Ohio EPA.
Step 4	**Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in November 2007.**

If you have any questions, please contact me at (937) 285-6114.

Sincerely,

David R. Secor

David R. Secor
Compliance Coordinator
Division of Drinking and Ground Waters

Enclosures

cc: Toni Buchanan, DDAGW, CO
Hamilton County Health Department

DS/ca

DRINKING WATER NOTICE
Tests showed coliform bacteria in RED WOOD MOBILE HOME PARK water

We routinely monitor for the presence of drinking water contaminants. We took Ten (10) samples for coliform bacteria during October 2007. Five (5) of those samples showed the presence of coliform bacteria. No more than [1 sample per month/5 percent of our samples] may show the presence of coliform bacteria during a month.

What should I do?

- **You do not need to boil your water or take other corrective actions.** However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.

- Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution systems.

- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*

  Fecal coliform or *E. coli*, which are bacteria of greater concern, were not detected in the follow-up testing.

What is being done?

We are still detecting coliform bacteria. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____ or _____.
name of contact phone number mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWS ID# OH3100112 Date distributed: _____

Tier 2: Unresolved Total Coliform Monthly MCL Notice

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NONCOMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
Use one or more of the following methods to reach all persons served by the public water system: Public notice issued by mail or other direct delivery to each customer receiving a bill and other other service connections to which water is delivered by the public water system.	Date of mailing/delivery_____
If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the public water system (e.g. publication in a local newspaper, delivery of multiple copies for distribution by customers that provide their drinking water to others, posting in public places served by the system or on the Internet, or deliver to community organizations). If the notice is posted, it shall remain in place as long as the violation exists, but in no case less than 7 days.	A. Method(s) _____ _____ _____ B. Date(s) _____

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

____ A public notice as shown on the other side of this sheet was issued without changes.
____ A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

_____ _____
Signature of Responsible Official Date

_____
Printed Name and Title of Responsible Official

RED WOOD MOBILE HOME PARK
NAME OF PUBLIC WATER SYSTEM

PWSID NUMBER: **OH3100112**

COUNTY NAME: **HAMILTON**

For OEPA use only **Date PN Received:** _____	**VIOLATION TYPE:** 22 **MONITORING PERIOD** October 2007
PN acceptable: **PN not acceptable:**	