



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

April 12, 2012

Re: **Licking County
Hebron Sunoco Public
Water System (PWS)
Transient Noncommunity Water System
PWS ID: OH4552512
STU ID: 4555628**

Art Schmitz
Certified Oil
949 King Avenue
Columbus, OH 43212

Dear Mr. Schmitz:

The Public Water System serving Hebron Sunoco is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that Certified Oil has not complied with requirements issued during this Agency's last survey performed on February 1, 2012 in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated February 6, 2012 to respond in writing no later than 30 days, with time frames for:

1. Grade the soils around the wellhead to prevent surface water from running towards the casing. Fill in the depressions nearby to prevent water from ponding near the casing.
2. Once you have picked out an alternate lab, fill out the sample siting plan and maintain it on site, and send a copy of the first page to this office.
3. Hire a certified water operator with at least a Class A license as your Operator of Record. You indicated via phone on January 31, 2012 that Joe Hickman is the operator for the Marathon station next door to the Hebron Sunoco, he would suffice. The Operator of Record needs to visit Hebron Sunoco at least once per week for at least one half hour of time. Whomever you choose, have them fill out the operator form and return a copy to this office. Ensure the operator properly records his visits in a logbook that remains on the property.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

4. Previous survey requirements include maintaining a sample siting plan on site. Ensure you or your operator maintains this document on site and has it, along with other records, available during future surveys. Other types of records that should be available for future surveys include recent laboratory results, owner/operator manuals for critical items such as well pumps, pressure tanks and treatment devices, and correspondence pertinent to the drinking water system.
5. Make this office aware of any substantial changes to your water system before any changes take place, as plan approval from this office prior to placing any new units in service is required.
6. Notify this office of any depressurizations (when system pressure drops below 20 psi) of the water system and properly disinfect the system.

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871 and my email is mark.boden@epa.state.oh.us.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

c: Licking County Health Department
CDO/DDAGW AA (State Violation)

ec: Mark Boden, DDAGW/CDO