



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

April 12, 2012

Re: Licking County  
Camp O'Bannon Camp & Pool  
Public Water Systems  
Transient Noncommunity Water Systems  
PWS ID's: OH4549412 & 4564212  
STU ID's: 4555617 & 4561282

Mr. Ted Cobb  
Camp O'Bannon  
9688 Butler Road NE  
Newark, OH 43055

Dear Mr. Cobb:

The Public Water Systems serving Camp O'Bannon is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that Camp O'Bannon has not complied with requirements issued during this Agency's last survey performed on February 22, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated February 29, 2012, to respond in writing no later than 30 days, with time frames for:

1. Protect both wells from damage by installing bumper posts, boulders, or a landscaping boulder at the well head. At the camp well, keep the weeds trimmed around the well head and install a PAS-97 cap with a screened, downturned vent similar to the pool well cap.
2. Once you have picked out an alternate lab, fill out the sample siting plans for each facility and maintain them on site, and send copies of the first page to this office.
3. Use only NSF or ANSI approved salt in your softeners. Check with the supplier to ensure it meets this standard. The softener for the camp needs replaced or removed from the water system.
4. Replace the corroded pressure gauge on the camp pressure tank.

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov

Mr. Ted Cobb  
Camp O'Bannon  
Page -2-

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871 and my email is mark.boden@epa.state.oh.us.

Sincerely,



Mark Boden  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

c: Licking County Health Department  
CDO/DDAGW AA (State Violation)

ec: Mark Boden, DDAGW/CDO

MB/ct 4549412(TypeSS)Mar2012