



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

April 12, 2012

Re: **Knox County
Lazy River at Granville Campground
Public Water System
Transient Noncommunity Water System
PWS ID: OH4558212
STU ID: 4555659**

Mark Kasper
Owner
Lazy River at Granville Campground
2340 Dry Creek Road
Granville, OH 43025

Dear Mr. Kasper:

The Public Water System serving the Lazy River at Granville Campground is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the Lazy River at Granville Campground has not complied with requirements issued during this Agency's last survey performed on February 13, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated March 8, 2012, to respond in writing no later than 30 days, with time frames for:

1. Once you have picked out an alternate lab, fill out the bacteriological sample siting plan and maintain it on site. Send a copy of the completed first page to this office. This was a requirement of the last survey which was conducted in 2005. Please make this available during future surveys.
2. Replace both well caps with ones that meet PAS-97 and have a downturned and screened vent. The cap on well #1 was broken and the cap on well number two does not have a downturned, screened vent. Both wells also need protection from vehicular traffic with the use of bumper posts (bollards) or boulders.
3. One of the pressure tanks near the back of the room needs replaced, the seams are rusting and the base is also corroded. Consider replacing it with a fiberglass tank. Also consider removing the salt stored adjacent to it.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

Mark Kasper
Lazy River at Granville Campground
Page -2-

4. The softener is defunct and is no longer in use and has been placed on bypass. Physically remove it from the water system and the treatment plant or replace it with a working unit.

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871 and my email is mark.boden@epa.state.oh.us.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

c: Knox County Health Department
DDAGW AA (State Violation)

ec: Mark Boden, DDAGW/CDO