





**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Neily, **Director**

Re: Defiance County  
Bethlehem Lutheran Church  
TNC Water System  
PWS ID # OH2030812

April 25, 2012

Mr. Daryl Neff  
Bethlehem Lutheran Church  
30997 Gerken Road  
Defiance, Ohio 43512

Dear Mr. Neff:

This letter will confirm removal of the water use advisory required in our letter dated, April 23, 2012. This is based on one set of four total coliform negative (safe) samples collected April 17, 2012, and received by our office on April 23, 2012.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, Ohio 43402 by May 9, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of May 2012.

Yours truly,

Clayton McKee  
Division of Drinking and Ground Waters

/cg

pc: Defiance County Health Department  
DDAGW, NWDO

