



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



NOTICE OF VIOLATION – ACTION REQUIRED

April 25, 2012

Mr. Lonnie C. Falknor
ODOT Rest Area 7-34 WB
1001 Saint Marys Avenue
Sidney, Ohio 45365

Auglaize County
ODOT Rest Area 7-34 WB
Transient Non-Community PWS
PWS ID: OH0634112

Dear Mr. Falknor:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system March 1, 2 and 3.

Chlorine for Community PWS (frequency and concentration)

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. OAC Rule 3745-83-01(G) (1) & (2) requires the public water system owner to monitor both the free and combined chlorine residuals at least once every day.

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Clayton McKee
Division of Drinking and Ground Waters

/cg

pc: DDAGW - NWDO

