





REGIONAL AIR POLLUTION CONTROL AGENCY

Serving Clark, Darke, Greene, Miami, Montgomery & Preble Counties

117 South Main Street, Dayton, Ohio 45422-1280

937-225-4435 — Fax: 937-225-3486

www.rapca.org

March 19, 2008

Certified Mail

Rafiq Bidiwala
Clark Gas Station
1020 Kauffman Ave
Fairborn, OH 45324

**RE: Ohio EPA Premises No. 0829060372
Failure to Pass Air to Liquid Ratio Test**

Dear Mr. Bidiwala:

WARNING LETTER

On January 16, 2008, the Regional Air Pollution Control Agency (RAPCA) conducted an inspection and witnessed a performance test of the gasoline dispensing facility (GDF) located at Clark Gas Station, 1020 Kauffman Avenue in Fairborn, Ohio. The purpose of this inspection and performance test was to determine the GDF's compliance status with applicable state and local air pollution control regulations. This inspection/test at the Clark Gas Station revealed violations of state and local air pollution control regulations.

Clark Gas Station did show compliance through the completion of a successful static pressure decay test on January 16, 2008, however, this site failed to show compliance with the Air to Liquid ratio (A/L) testing requirements of CARB Executive Order G-70-153-AD on pumps #1, #2 and #6. Failing to demonstrate compliance with the A/L performance test requirements is a violation of Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD), OAC rule and GCBHAPCR section 3745-15-04, and Ohio Revised Code (ORC) section 3704.05. On January 16, 2008, an Official Order was issued to Clark Gas Station to make any needed repairs and reschedule testing within a thirty (30) day time period. To this date, no A/L retest has been scheduled with RAPCA.

Since the above noted GDF is currently operating in violation of OAC rules and GCBHAPCR sections 3745-21-09 (DDD) and 3745-15-04, and CARB Executive Order G-70-153-AD, it is imperative that Clark Gas Station ensure that repairs are made to this site to correct the deficiencies, and reschedule A/L testing to demonstrate compliance.

Clark Gas Station shall respond within fourteen (14) days after receipt of this letter. The response shall include the intended retest date for this GDF. Your tester should

Clark Gas Station
March 19, 2008
Page 2

contact Lynn Thompson at (937) 225-4437, to ensure a RAPCA representative is present at your scheduled testing.

Failure to perform the required testing will subject this facility to further enforcement actions, which may include penalties. If you have any questions or comments concerning this matter, please feel free to contact me at (937) 225-5923.

Sincerely,



Brandie K. Lehman
Air Pollution Control Specialist

cc:	Jeff Canan	RAPCA
	Tom Kalman	OEPA
	Lisa Holscher	USEPA

**REGIO**

Serving:

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

**RAFIQ BIDIWALA
CLARK GAS STATION
1020 KAUFFMAN AVENUE
FAIRBORN, OH 45324**

2. Article Number
(Transfer from service)**7004 1160 0000 6165 4627**

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1

COMPLETE THIS SECTION ON DELIVERY

A. Signature X J. Brown		<input type="checkbox"/> Agent
B. Received by (Printed Name)		<input type="checkbox"/> Addressee
C. Date of Delivery		
D. Is delivery address different from item 1? If YES, enter delivery address below:		<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Service Type <input checked="" type="checkbox"/> Certified Mail		<input type="checkbox"/> Express Mail
<input type="checkbox"/> Registered		<input type="checkbox"/> Return Receipt for Merchandise
<input type="checkbox"/> Insured Mail		<input type="checkbox"/> C.O.D.
4. Restricted Delivery? (Extra Fee)		<input type="checkbox"/> Yes

Certified Mail

Rafiq Bidiwala
Clark Gas Station
1020 Kauffman Ave
Fairborn, OH 45324

**RE: Ohio EPA Premises No. 0829060372
Failure to Pass Air to Liquid Ratio Test**

Dear Mr. Bidiwala:

WARNING LETTER

On January 16, 2008, the Regional Air Pollution Control Agency (RAPCA) conducted an inspection and witnessed a performance test of the gasoline dispensing facility (GDF) located at Clark Gas Station, 1020 Kauffman Avenue in Fairborn, Ohio. The purpose of this inspection and performance test was to determine the GDF's compliance status with applicable state and local air pollution control regulations. This inspection/test at the Clark Gas Station revealed violations of state and local air pollution control regulations.

Clark Gas Station did show compliance through the completion of a successful static pressure decay test on January 16, 2008, however, this site failed to show compliance with the Air to Liquid ratio (A/L) testing requirements of CARB Executive Order G-70-153-AD on pumps #1, #2 and #6. Failing to demonstrate compliance with the A/L performance test requirements is a violation of Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD), OAC rule and GCBHAPCR section 3745-15-04, and Ohio Revised Code (ORC) section 3704.05. On January 16, 2008, an Official Order was issued to Clark Gas Station to make any needed repairs and reschedule testing within a thirty (30) day time period. To this date, no A/L retest has been scheduled with RAPCA.

Since the above noted GDF is currently operating in violation of OAC rules and GCBHAPCR sections 3745-21-09 (DDD) and 3745-15-04, and CARB Executive Order G-70-153-AD, it is imperative that Clark Gas Station ensure that repairs are made to this site to correct the deficiencies, and reschedule A/L testing to demonstrate compliance.

Clark Gas Station shall respond within fourteen (14) days after receipt of this letter. The response shall include the intended retest date for this GDF. Your tester should