





## REGIONAL AIR POLLUTION CONTROL AGENCY

Serving Clark, Darke, Greene, Miami, Montgomery & Preble Counties

117 South Main Street, Dayton, Ohio 45422-1280

937-225-4435 — Fax: 937-225-3486

www.rapca.org

July 7, 2008

**Certified Mail**

Mike Peacock

Duncan Oil Company

849 Factory Road

Beavercreek, OH 45434

**RE: Ohio EPA Facility ID 0829790419**

**Spring Valley General Store – 1616 W. Spring Valley-Paintersville Rd, Spring Valley, OH  
Failure to perform annual stage II vapor recovery compliance testing**

**WARNING LETTER**

Dear Mr. Peacock:

Pursuant to Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD)(2), the stage II vapor control system at the Spring Valley General Store gasoline dispensing facility (GDF) located at 1616 West Spring Valley-Paintersville Road in Spring Valley, Ohio, must perform and successfully pass the testing requirements contained in OAC rule 3745-21-10. In accordance with the yearly static pressure decay testing requirements specified in CARB Executive Order G-70-150-AE and the Static Leak Test contained in OAC rule 3745-21-10, Appendix A, Static Leak testing and Air to Liquid Ratio (A/L) testing shall be successfully conducted at least once in each twelve consecutive month period after the date of successful completion of the startup or most recent Static Leak Test.

OAC rule and GCBHAPCR section 3745-21-09(DDD)(1) state: "no owner or operator of a gasoline dispensing facility may cause, allow or permit the transfer of gasoline from a stationary storage tank at a GDF into a motor vehicle . . . unless the following requirements are met: . . .

(c) The vapor control system has successfully passed the testing requirements contained in paragraph (DDD)(2) of this rule." This GDF is required to demonstrate compliance on an annual basis. The last annual stage II vapor recovery compliance test conducted at Spring Valley General Store was on December 7, 2006. On April 15, 2008, an Official Order was issued to Spring Valley General Store for failing to perform an annual stage II vapor recovery compliance test. Testing was scheduled at this site for May 19, 2008, but was unable to be performed due to low fuel tank levels. A second Official Order was issued to Spring Valley General Store on this

Spring Valley General Store

July 7, 2008

Page 2

date, and required Spring Valley General Store to reschedule testing within thirty (30) days. To date, no additional testing has been scheduled with the Regional Air Pollution Control Agency (RAPCA) at this site. Spring Valley General Store is currently operating in violation of OAC rule and GCBHAPCR section 3745-21-09 (DDD)(2) and the prohibitions in Ohio Revised Code (ORC) section 3704.05.

This letter serves as official notification from RAPCA to cease operation in violation of OAC rule and GCBHAPCR section 3745-21-09 (DDD)(2) and ORC section 3704.05. It is imperative that Spring Valley General Store schedule and show compliance with stage II testing requirements. **Please respond, in writing, to this notice within fourteen (14) days after receipt of this letter. The response will specify the intended test date.** Your tester should contact Lynn Thompson, at (937) 225-4437, to ensure a RAPCA representative is present at your scheduled testing.

Failure to perform the required testing will subject this facility to further enforcement actions, which may include penalties. If you have any questions or comments concerning this matter, please feel free to contact me at (937) 225-5923.

Sincerely,



Brandie K. Lehman  
Air Pollution Control Specialist  
Abatement Unit

cc: Jeff Canan                      RAPCA  
Tom Kalman                        OEPA  
Lisa Holscher                      USEPA



REGIO  
Servin

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

MIKE PEACOCK  
DUNCAN OIL CO  
849 FACTORY RD  
BEAVERCREEK, OH 45434

2. Article Number  
(Transfer from service label)

7007 1490 0004 7510 0371

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-44-11

**COMPLETE THIS SECTION ON DELIVERY**

- A. Signature  Agent  Addressee  
 X *V. Rowland*
- B. Received by (Printed Name)  Yes  No  
*V. ROWLAND*
- C. Date of Delivery  
*July*
- D. Is delivery address different from item 1?  Yes  No  
 If YES, enter delivery address below:

3. Service Type  Certified Mail  Express Mail  
 Registered  Return Receipt for Merchandis  
 Insured Mail  C.O.D.
4. Restricted Delivery? (Extra Fee)  Yes

Certified Mail

Mike Peacock  
Duncan Oil Company  
849 Factory Road  
Beavercreek, OH 45434

RE: Ohio EPA Facility ID 0829790419  
Spring Valley General Store – 1616 W. Spring Valley-Paintersville Rd, Spring Valley, OH  
Failure to perform annual stage II vapor recovery compliance testing

WARNING LETTER

Dear Mr. Peacock:

Pursuant to Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD)(2), the stage II vapor control system at the Spring Valley General Store gasoline dispensing facility (GDF) located at 1616 West Spring Valley-Paintersville Road in Spring Valley, Ohio, must perform and successfully pass the testing requirements contained in OAC rule 3745-21-10. In accordance with the yearly static pressure decay testing requirements specified in CARB Executive Order G-70-150-AE and the Static Leak Test contained in OAC rule 3745-21-10, Appendix A, Static Leak testing and Air to Liquid Ratio (A/L) testing shall be successfully conducted at least once in each twelve consecutive month period after the date of successful completion of the startup or most recent Static Leak Test.

OAC rule and GCBHAPCR section 3745-21-09(DDD)(1) state: "no owner or operator of a gasoline dispensing facility may cause, allow or permit the transfer of gasoline from a stationary storage tank at a GDF into a motor vehicle . . . unless the following requirements are met: . . . (c) The vapor control system has successfully passed the testing requirements contained in paragraph (DDD)(2) of this rule." This GDF is required to demonstrate compliance on an annual basis. The last annual stage II vapor recovery compliance test conducted at Spring Valley General Store was on December 7, 2006. On April 15, 2008, an Official Order was issued to Spring Valley General Store for failing to perform an annual stage II vapor recovery compliance test. Testing was scheduled at this site for May 19, 2008, but was unable to be performed due to low fuel tank levels. A second Official Order was issued to Spring Valley General Store on this

