





## **REGIONAL AIR POLLUTION CONTROL AGENCY**

Serving Clark, Darke, Greene, Miami, Montgomery & Preble Counties

117 South Main Street, Dayton, Ohio 45422-1280

937-225-4435 — Fax: 937-225-3486

www.rapca.org

November 19, 2009

**Certified Mail**

Umar Dhadha

Troy Petroleum, LLC

1010 North Broad Street

Fairborn, OH 45324

**RE: Ohio EPA Facility ID 0829060371  
Clark Gas Station - 1010 North Broad Street, Fairborn, OH 45324  
Failure to Pass Air to Liquid Ratio Test**

Dear Mr. Dhadha:

**WARNING LETTER**

On October 15, 2009, the Regional Air Pollution Control Agency (RAPCA) conducted an inspection and witnessed a performance test of the gasoline dispensing facility (GDF) located at Clark Gas Station, 1010 North Broad Street in Fairborn, Ohio. The purpose of this inspection and performance test was to determine the GDF's compliance status with applicable state and local air pollution control regulations. This inspection/test at Clark Gas Station revealed violations of these regulations.

Clark Gas Station did show compliance through the completion of a successful static leak test and dynamic pressure performance test on October 15, 2009, however, this site failed to show compliance with the Air to Liquid ratio (A/L) testing requirements of CARB Executive Order G-70-154-AA on pumps #1, #2, & #3. Failing to demonstrate compliance with the A/L performance test requirements is a violation of Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD), OAC rule and GCBHAPCR section 3745-15-04, and Ohio Revised Code (ORC) section 3704.05. An Official Order was issued by RAPCA to Clark Gas Station on October 15, 2009 to make any needed repairs and reschedule testing within a thirty (30) day time period. To date, no A/L retest has been scheduled with RAPCA at Clark Gas Station.

Since the above noted GDF is currently operating in violation of OAC rules and GCBHAPCR sections 3745-21-09 (DDD) and 3745-15-04, and CARB Executive Order G-70-

Clark Gas Station  
November 19, 2009  
Page 2

154-AA, it is imperative that Clark Gas Station ensure that repairs are made to this site to correct the deficiencies, and reschedule A/L testing to demonstrate compliance.

**Clark Gas Station shall respond within fourteen (14) days after receipt of this letter.** The response shall include the intended retest date for this GDF. Your tester should contact Lynn Thompson at (937) 225-4437, to ensure a RAPCA representative is present at your scheduled testing.

Failure to perform the required testing will subject this facility to further enforcement actions, which may include penalties. If you have any questions or comments concerning this matter, please feel free to contact me at (937) 225-5923.

Sincerely,



Brandie K. Lehman  
Air Pollution Control Specialist

cc:	Jeff Canan	RAPCA
	Tom Kalman	OEPA
	Lisa Holscher	USEPA

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

Article Addressed to:  
  
Jmar Dhadha  
Troy Petroleum, LLC  
1010 North Broad St.  
Fairborn, OH 45324

**COMPLETE THIS SECTION ON DELIVERY**

A. Signature  
 *A. Paul*  Agent  
 Addressee

B. Received by (Printed Name) C. Date of Delivery

D. Is delivery address different from item 1?  Yes  
 If YES, enter delivery address below:  No



3. Service Type  
 Certified Mail  Express Mail  
 Registered  Return Receipt for Merchandise  
 Insured Mail  C.O.D.

4. Restricted Delivery? (Extra Fee)  Yes

Article Number  
 Transfer from service label) 7008 1830 0003 0181 0071

**CONTROL AGENCY**

Primary & Preble Counties  
 Phone 45422-1280  
 Fax 45422-3486

RE: Ohio EPA Facility ID 0829060371  
 Clark Gas Station - 1010 North Broad Street, Fairborn, OH 45324  
 Failure to Pass Air to Liquid Ratio Test

Dear Mr. Dhadha:

**WARNING LETTER**

On October 15, 2009, the Regional Air Pollution Control Agency (RAPCA) conducted an inspection and witnessed a performance test of the gasoline dispensing facility (GDF) located at Clark Gas Station, 1010 North Broad Street in Fairborn, Ohio. The purpose of this inspection and performance test was to determine the GDF's compliance status with applicable state and local air pollution control regulations. This inspection/test at Clark Gas Station revealed violations of these regulations.

Clark Gas Station did show compliance through the completion of a successful static leak test and dynamic pressure performance test on October 15, 2009, however, this site failed to show compliance with the Air to Liquid ratio (A/L) testing requirements of CARB Executive Order G-70-154-AA on pumps #1, #2, & #3. Failing to demonstrate compliance with the A/L performance test requirements is a violation of Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD), OAC rule and GCBHAPCR section 3745-15-04, and Ohio Revised Code (ORC) section 3704.05. An Official Order was issued by RAPCA to Clark Gas Station on October 15, 2009 to make any needed repairs and reschedule testing within a thirty (30) day time period. To date, no A/L retest has been scheduled with RAPCA at Clark Gas Station.

Since the above noted GDF is currently operating in violation of OAC rules and GCBHAPCR sections 3745-21-09 (DDD) and 3745-15-04, and CARB Executive Order G-70-

