



REGIONAL AIR POLLUTION CONTROL AGENCY

Serving Clark, Darke, Greene, Miami, Montgomery & Preble Counties

117 South Main Street, Dayton, Ohio 45422-1280

937-225-4435 — Fax: 937-225-3486

www.rapca.org

January 13, 2011

Certified Mail

Amarjit Singh
PAP Oil Company LLC
4365 Lisa Drive
Tipp City, OH 45371

**RE: Ohio EPA Facility ID 0829100326 - Hometown Valero, 296 Home Ave, Xenia, OH
Failure to perform annual stage II vapor recovery compliance testing**

WARNING LETTER

Dear Mr. Singh:

Pursuant to Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD)(2), the Gilbarco VaporVac stage II vapor recovery system at the Hometown Valero gasoline dispensing facility (GDF) located at 296 Home Avenue in Xenia, Ohio, must perform and successfully pass the testing requirements contained in OAC rule 3745-21-10 and any applicable CARB certification. In accordance with the yearly static pressure decay and air to liquid ratio (A/L) testing requirements specified in CARB Executive Order G-70-150-AE, for Gilbarco VaporVac stage II vapor recovery systems, and the static leak test contained in OAC rule 3745-21-10, Appendix A, static leak testing and A/L testing shall be successfully conducted at least once in each twelve consecutive month period after the date of successful completion of the startup or most recent static leak test.

OAC rule and GCBHAPCR section 3745-21-09 (DDD)(1) state: "no owner or operator of a gasoline dispensing facility may cause, allow or permit the transfer of gasoline from a stationary storage tank at a GDF into a motor vehicle . . . unless the following requirements are met: . . . (c) The vapor control system has successfully passed the testing requirements contained in paragraph (DDD)(2) of this rule." This GDF is required to demonstrate compliance on an annual basis. The last successful annual stage II vapor recovery compliance test conducted at this GDF was on September 9, 2009, under previous ownership. On October 6, 2010, the Regional Air Pollution Control Agency (RAPCA) issued an Official Order, to the previous owner, requiring testing be scheduled within thirty (30) days of the issuance of that Order. No testing was scheduled with RAPCA at Hometown Valero within the 30 day timeframe given. RAPCA sent a

Hometown Valero
January 13, 2011
Page 2

follow-up email to the previous owner of Hometown Valero on November 19, 2010, requesting that the annual stage II vapor recovery compliance testing be scheduled. RAPCA was informed by the previous owner of Hometown Valero, on November 22, 2010, that this GDF was sold to you on October 14, 2010. On November 23, 2010, RAPCA issued an Official Order, to your attention, requiring testing be scheduled at Hometown Valero within 30 days of the issuance of that Order. To date, no testing has been scheduled with RAPCA at this site. Hometown Valero is currently operating in violation of OAC rules and GCBHAPCR sections 3745-21-09 (DDD)(1) and (2), CARB Executive Order G-70-150-AE and the prohibitions in Ohio Revised Code (ORC) section 3704.05.

This letter serves as official notification from RAPCA to cease operation in violation of OAC rules and GCBHAPCR sections 3745-21-09 (DDD)(1) and (2), CARB Executive Order G-70-150-AE and ORC section 3704.05. It is imperative that Hometown Valero schedule and show compliance with stage II testing requirements. **Please respond to this notice within fourteen (14) days after receipt. The response will specify the intended test date.** Your tester should contact Lynn Thompson, at (937) 225-4437, to ensure a RAPCA representative is present at your scheduled testing.

Failure to perform the required testing will subject this facility to further enforcement actions, which may include penalties. If you have any questions or comments concerning this matter, please feel free to contact me at (937) 225-5923.

Sincerely,



Brandie K. Lehman
Air Pollution Control Specialist

Cc: Jeff Canan RAPCA
Tom Kalman OEPA
William MacDowell USEPA

COMPLETE THIS SECTION

Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Amarjit Singh
 PAP Oil Company, LLC
 4365 Lisa Drive
 Tipp City, Ohio 45371

COMPLETE THIS SECTION ON DELIVERY

A. Signature Agent Addressee
[Signature]
 B. Received by (Printed Name) *DEB SINGH* C. Date of Delivery
 D. Is delivery address different from item 1? Yes No
 If YES, enter delivery address below:

Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

Article Number (Transfer from service label) 7002 0510 0000 7312 1366

S Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540

POLLUTION CONTROL AGENCY

Greene & Preble Counties
 45422-1280
 937-25-3486

RE: Ohio EPA Facility ID 0829100326 - Hometown Valero, 296 Home Ave, Xenia, OH
 Failure to perform annual stage II vapor recovery compliance testing

WARNING LETTER

Dear Mr. Singh:

Pursuant to Ohio Administrative Code (OAC) rule and Greene County Board of Health Air Pollution Control Regulations (GCBHAPCR) section 3745-21-09 (DDD)(2), the Gilbarco VaporVac stage II vapor recovery system at the Hometown Valero gasoline dispensing facility (GDF) located at 296 Home Avenue in Xenia, Ohio, must perform and successfully pass the testing requirements contained in OAC rule 3745-21-10 and any applicable CARB certification. In accordance with the yearly static pressure decay and air to liquid ratio (A/L) testing requirements specified in CARB Executive Order G-70-150-AE, for Gilbarco VaporVac stage II vapor recovery systems, and the static leak test contained in OAC rule 3745-21-10, Appendix A, static leak testing and A/L testing shall be successfully conducted at least once in each twelve consecutive month period after the date of successful completion of the startup or most recent static leak test.

OAC rule and GCBHAPCR section 3745-21-09 (DDD)(1) state: "no owner or operator of a gasoline dispensing facility may cause, allow or permit the transfer of gasoline from a stationary storage tank at a GDF into a motor vehicle . . . unless the following requirements are met: . . . (c) The vapor control system has successfully passed the testing requirements contained in paragraph (DDD)(2) of this rule." This GDF is required to demonstrate compliance on an annual basis. The last successful annual stage II vapor recovery compliance test conducted at this GDF was on September 9, 2009, under previous ownership. On October 6, 2010, the Regional Air Pollution Control Agency (RAPCA) issued an Official Order, to the previous owner, requiring testing be scheduled within thirty (30) days of the issuance of that Order. No testing was scheduled with RAPCA at Hometown Valero within the 30 day timeframe given. RAPCA sent a

