





**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Re: Sandusky County
Lazy River Campground
TNC Water System
PWS ID # OH7245312

April 26, 2012

Mr. Eric Walters
Lazy River Campground
1950 County Road 41
Fremont, Ohio 43420

Dear Mr. Walters:

This letter will confirm removal of the water use advisory required in our letter dated December 8, 2011. This is based on one set of four total coliform negative (safe) samples collected April 17, 2012.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by May 10, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five temporary routine samples prior to opening to the public for the 2012 season.

Yours truly,

Janis D'Amico
Division of Drinking and Ground Waters

/llr

pc: Sandusky County Health Department
DDAGW, NWDO

(

(