



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 21, 2010

Art Chonko
Denison University
1205 N. Perl Street
Granville, OH 43023

**Re: Storm Water Inspection at Little Cleveland Hall
Permit Number 4GC02404*AG**

Dear Mr. Chonko:

This letter is written regarding the storm water inspection I conducted at Cleveland Hall located in Granville, Ohio on March 31, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- It appears construction is complete and vegetation is becoming established. Successful vegetation, in accordance with the permit conditions, is measured by a minimum vegetative density of 70 percent. Please continue to monitor the vegetative density at this site to ensure the minimum requirements are met.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: [Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Art Chonko
Denison University
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Cleveland Hall 3-31-2010