



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 15, 2010

Paul Ryan
Columbus Regional Airport Authority
7161 Second Street
Columbus, OH 43217

**Re: Rickenbacker Parkway – Phase 2A / Franklin County
Permit Number 4GC03205*AG**

Dear Mr. Ryan:

This letter is written in regard to a construction storm water inspection that I conducted at the Rickenbacker Parkway – Phase 2A, from Lockbourne Eastern Road to Port Road, Columbus, Ohio on September 3, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Storm drains were adequately protected with silt fences.
- A log of the inspections was not kept at the site. A log of the inspections must be kept at the site.
- A copy of the storm water pollution prevention plan was not kept at the site. Please keep a copy of the storm water pollution prevention plan at the site.
- Please install a concrete wash-out pit at the site.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Rickenbacker Pkwy, Phase 2A, Sept. 3, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



