



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 15, 2010

Chris Kloiberjohn Burkemper
Amcon Design & Construction Co. LLC
20633 Watertown Ct. Ste. 200
Waukesha, WI 53186

Re: Bridgestone/Firestone Auto Service Facility / Franklin County

Dear Mr. Burkemper:

This letter is written in follow-up to a construction storm water inspection that I conducted at Bridgestone/Firestone Auto Service Facility located near Waterloo and Gender Roads, in Canal Winchester, Ohio, on September 1, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- A concrete wash-out pit is needed for this site. Please install a concrete wash-out pit.
- Additional stone may be needed for your construction entrances at the site. Please use additional stone if mud starts to be tracked off-site.
- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of the inspections must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Bridgestone Firestone Auto Service Facility, September 1, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Steve Geiger
Geiger Excavating Inc.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Bedford II Landfill Cover 7-26-2010