



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Caesar Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 14, 2010

Mr. Cooper and Mr. Campbell
Master Church Builders
1667 Gateway Circle
Grove City, OH 43123

Re: Crossroads Christian Church / Fayette County

Dear Mr. Cooper and Mr. Campbell:

This letter is written in follow-up to a construction storm water inspection that I conducted at Crossroads Christian Church in Washington Court House, Ohio on August 31, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The retention basin noted onsite must be modified to address sediment control via the installation of a temporary riser. I understand that there is a temporary plug in the downstream pipe at this time. However, a riser would be much more effective and cause less problems. Trying to dewater the pond and remove the plug could be very cumbersome and allow solids to discharge from the site.
- The concrete wash-out pit is full of hardened concrete. Please install a new concrete wash-out pit. Please see attached picture.
- Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within 7 days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within 7 days. Please see attached picture.
- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Mr. Cooper and Mr. Campbell
Master Church Builders
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,



Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosure

c: jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Crossroads Christian Church, August 31, 2010

**Crossroads Christian Church
Need to install new concrete wash pit
Paint Creek Watershed
August 31, 2010
Photo by: Greg Sanders**



**Crossroads Christian Church
Stabilize barren areas
Paint Creek Watershed
August 31, 2010
Photo by: Greg Sanders**



