



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 14, 2010

Tom Ekegren
Ohio State University
400 Central Classroom Bldg-Millikin Road
Columbus OH 43210

**Re: Construction Storm Water Inspection at Lot Q- Drackett
1100 Kinnear Road, Franklin County.
Permit Number: 4GC03311*AG**

Dear Mr. Ekegren:

This letter is written regarding a storm water inspection conducted by Vinod Tujalpuram of Ohio EPA, at Lot Q-Drackett located Southeast of Neil Avenue in Columbus on August 26, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- It appears all sediment and erosion controls were in place, and are functioning as intended. Please continue to maintain all storm water and sediment controls to ensure continued compliance with the requirements of your General Storm Water Permit.

Maintenance:

- The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Tom Ekegren
Ohio State University
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Lot Q Drackett & 1100 Kinnear Drive, 8-26-2010