



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 10, 2010

John Burkemper
Amcon Design and Construction Company LLC
20633 Watertown Court, Suite 200
Waukesha, WI 53186

**Re: Pre-Construction Storm Water Inspection at Firestone Auto Service Facility
Franklin County
Permit Number: 4GC03260*AG**

Dear Mr. Burkemper:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Stephen Riley of Ohio EPA at Firestone Auto Service Facility located at Winchester Boulevard and Waterloo Street in Canal Winchester, Ohio on August 25, 2010. The agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. The following items were noted:

Sediment and Erosion Controls:

- It appears the grading on site along the west Waterloo Street is barren. To minimize vehicle tracking of dirt on to the street, a silt fence must be established along the curb at this time. Corrective measures are expected within three days from receipt of this letter.

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



John Burkemper
Amcon Design and Construction Company LLC
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/DSW

HK/nsm Firestone Auto Service Facility 8-25-2010