

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 26, 2012

RE: **NOTICE OF VIOLATION**
MAHONING COUNTY
SOUTH RANGE LOCAL SCHOOLS K-12
NON-TRANSIENT PWS
PWS ID #OH5054712

CERTIFIED MAIL

7004 2510 0002 4075 2227

Mr. Dennis Dunham
South Range Local Schools
11822 South Avenue
North Lima, OH 44452

Dear Mr. Dunham:

This letter is notification that the South Range Local Schools K-12 Public Water System (PWS) is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points in the distribution system.

This violation of the OAC is based upon information submitted by the South Range Local Schools K-12 PWS as reported on Monthly Operating Report (MOR) #5002 for the months of **September 2011 through March 2012**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was less than 0.2 mg/L or was not recorded.

Reporting Month	Number of days the free chlorine residual < 0.2 mg/L
September 2011	13
October 2011	15
November 2011	16
December 2011	19
January 2012	22
February 2012	8
March 2012	15

An evaluation/investigation should be conducted to determine why the low residuals are occurring and what corrective action is necessary. Please provide a written explanation within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,



Chris Maslo
Environmental Specialist
Division of Drinking and Ground Waters

CM:ds

cc: Firl Byers, Certified Operator