

**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

April 26, 2012

RE: **NOTICE OF VIOLATION**
STARK COUNTY
HARTVILLE MARKETPLACE
TRANSIENT PUBLIC WATER SYSTEM
PWS ID #OH7673312

CERTIFIED MAIL

7004 2510 0002 4075 2234

Mr. Richard Wittmer
Hartville Marketplace
1089 Edison Street
Hartville, OH 44632

Dear Mr. Wittmer:

This letter is notification that the Hartville Marketplace Public Water System (PWS) is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points in the distribution system.

This violation of the OAC is based upon information submitted by the Hartville Marketplace PWS as reported on Monthly Operating Report (MOR) #5002 for the months of **November 2011 through February 2012**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was less than 0.2 mg/L or was not recorded.

Reporting Month	Number of days the free chlorine residual < 0.2 mg/L
November 2011	5
December 2011	7
January 2012	14
February 2012	12

An evaluation/investigation should be conducted to determine why the low residuals are occurring and what corrective action is necessary. Please provide a written explanation within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,



Chris Maslo
Environmental Specialist
Division of Drinking and Ground Waters

CM:ds