



REGIONAL AIR POLLUTION CONTROL AGENCY

Serving Clark, Darke, Greene, Miami, Montgomery & Preble Counties

117 South Main Street, Dayton, Ohio 45422-1280

937-225-4435 — Fax: 937-225-3486

www.rapca.org

February 12, 2008

Certified Mail

Missy Stanaway

Speedway SuperAmerica LLC

P.O. Box 1500

Springfield, OH 45501

**RE: Ohio EPA Premises No. 0857171370
Speedway SuperAmerica #9616 – 830 E. National Rd., Vandalia, OH
Failure to Pass Annual Stage II Vapor Recovery Compliance Testing**

Dear Ms. Stanaway:

WARNING LETTER

On December 19, 2007, the Regional Air Pollution Control Agency (RAPCA) conducted an inspection and witnessed a performance test of the gasoline dispensing facility (GDF) at Speedway SuperAmerica LLC #9616 (SSA #9616) located at 830 East National Road in Vandalia, Ohio. The purpose of this inspection and performance test was to determine the GDF's compliance status with applicable state and local air pollution control regulations. This inspection/test at SSA #9616 revealed violations of state and local air pollution control regulations.

Pursuant to Ohio Administrative Code (OAC) rule and Montgomery County Combined General Health District Air Pollution Control Regulations (MCCGHDAPCR) section 3745-21-09 (DDD)(2), and in accordance with the testing requirements specified in CARB Executive Order G-70-153-AD, static leak testing contained in OAC rule 3745-21-10, Appendix A, and air to liquid ratio (A/L) testing shall be successfully conducted at least once in each consecutive twelve-month period. SSA #9616 failed to show compliance with OAC rule and MCCGHDAPCR section 3745-21-09 (DDD)(2), through the completion of a successful static leak test and A/L test on December 19, 2007.

Failing to demonstrate compliance with the testing requirements is a violation of OAC rule and MCCGHDAPCR section 3745-21-09 (DDD)(2), OAC rule and MCCGHDAPCR section 3745-15-04, and Ohio Revised Code (ORC) section 3704.05.

Since the above noted GDF is currently operating in violation of OAC rules and MCCGHDAPCR sections 3745-21-09 (DDD) and 3745-15-04, and CARB Executive


Speedway SuperAmerica LLC #9616
February 12, 2008
Page 2

Order G-70-153-AD, it is imperative that SSA #9616 ensure that repairs are made to this site to correct the deficiencies, and reschedule testing to demonstrate compliance.

SSA #9616 shall respond within fourteen (14) days after receipt of this letter. The response shall include the intended retest date for this GDF. Your tester should contact Lynn Thompson at (937) 225-4437, to ensure a RAPCA representative is present at your scheduled testing.

Failure to perform the required testing will subject this facility to further enforcement actions, which may include penalties. If you have any questions or comments concerning this matter, please feel free to contact me at (937) 225-5923.

Sincerely,



Brandie K. Lehman
Air Pollution Control Specialist

cc: Jeff Canan RAPCA
Tom Kalman OEPA
Lisa Holscher USEPA

SENDER: COMPLETE THIS SECTION

COMPLETE THIS SECTION ON DELIVERY

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

A. Signature
 X *Judy Ernie* Age Add

B. Received by (Printed Name) C. Date of Delivery
 FEB 14

D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

1. Article Addressed to:

MISSY STANAWAY
 SPEEDWAY SUPERAMERICA LLC
 PO BOX 1500
 SPRINGFIELD, OH 45501

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merch
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

2. Article Number
 (Transfer from service label)

7004 1160 0000 6165 4443

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-1

UNITED STATES POSTAL SERVICE



First-Class Mail
 Postage & Fees Paid
 USPS
 Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

RAPCA
 BRANDIE LEHMAN
 117 S MAIN STREET
 DAYTON, OH 45422-1280

RECEIVED

FEB 15 2008

REGIONAL AIR POLLUTION CONTROL

