



REGIONAL AIR POLLUTION CONTROL AGENCY

Serving Clark, Darke, Greene, Miami, Montgomery & Preble Counties

117 South Main Street, Dayton, Ohio 45422-1280

937-225-4435 — Fax: 937-225-3486

www.rapca.org

October 27, 2010

Certified Mail

Vicky D. Quillen
Moraine Drive Thru
2901 Main Street
Moraine, OH 45439

**RE: Ohio EPA Facility ID 0857102062
Failure to Pass Air to Liquid Ratio Test**

Dear Ms. Quillen:

WARNING LETTER

On May 17, 2010 and June 30, 2010, the Regional Air Pollution Control Agency (RAPCA) conducted inspections and witnessed performance tests of the gasoline dispensing facility (GDF) at Moraine Drive Thru, 2901 Main Street in Moraine, Ohio. The purpose of these inspections and performance tests was to determine the GDF's compliance status with applicable state and local air pollution control regulations. These inspections/tests at Moraine Drive Thru revealed violations of these regulations.

Moraine Drive Thru did show compliance through the completion of a successful static leak test on the Tokheim stage II vapor control system for pumps #1 through #8 on May 17, 2010 and a successful static leak test and dynamic pressure performance test on the Balance stage II vapor control system for the Turbo Blue pumps on June 30, 2010, however, this site failed to show compliance with the Air to Liquid ratio (A/L) testing requirements of CARB Executive Order G-70-154-AA on pumps #5 and #7 on these dates. Failing to demonstrate compliance with the A/L testing requirement is a violation of Ohio Administrative Code (OAC) rule and Montgomery County Combined General Health District Air Pollution Control Regulations (MCCGHDAPCR) section 3745-21-09 (DDD), CARB Executive Order G-70-154-AA, and Ohio Revised Code (ORC) 3704.05. On June 30, 2010, an Official Order was issued to Moraine Drive Thru to make any needed repairs and reschedule A/L testing within a thirty (30) day time period. To date, no A/L retest has been scheduled with RAPCA at this GDF.

Since the above noted GDF is currently operating in violation of OAC rule and MCCGHDAPCR section 3745-21-09 (DDD), CARB Executive Order G-70-154-AA and ORC

Moraine Drive Thru
October 27, 2010
Page 2

3704.05, it is imperative that Moraine Drive Thru ensure that repairs are made to this site to correct the deficiencies, and reschedule A/L testing to demonstrate compliance.

Moraine Drive Thru shall respond within fourteen (14) days after receipt of this letter. The response shall include the intended retest date for this GDF. Your tester should contact Lynn Thompson at (937) 225-4437, to ensure a RAPCA representative is present at your scheduled testing.

Failure to perform the required testing will subject this facility to further enforcement actions, which may include penalties. If you have any questions or comments concerning this matter, please feel free to contact me at (937) 225-5923.

Sincerely,



Brandie K. Lehman
Air Pollution Control Specialist

cc:	Jeff Canan	RAPCA
	Tom Kalman	OEPA
	William MacDowell	USEPA, Region V

COMPLETE THIS SECTION

Items 1, 2, and 3. Also complete if Restricted Delivery is desired. Attach your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Vicky Quillen
Moraine Drive Thru
2901 Main Street
Moraine, Ohio 45439

COMPLETE THIS SECTION ON DELIVERY

A. Signature

Dennis Blaney

Agent
 Addressee

B. Received by (Printed Name)

C. Date of Delivery

D. Is delivery address different from item 1? Yes
If YES, enter delivery address below: No

3. Service Type

Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

2. Article Number

7010 1060 0000 0187 3127

(Transfer from service label)

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540

RE: Ohio EPA Facility ID 0857102062
Failure to Pass Air to Liquid Ratio Test

Dear Ms. Quillen:

WARNING LETTER

On May 17, 2010 and June 30, 2010, the Regional Air Pollution Control Agency (RAPCA) conducted inspections and witnessed performance tests of the gasoline dispensing facility (GDF) at Moraine Drive Thru, 2901 Main Street in Moraine, Ohio. The purpose of these inspections and performance tests was to determine the GDF's compliance status with applicable state and local air pollution control regulations. These inspections/tests at Moraine Drive Thru revealed violations of these regulations.

Moraine Drive Thru did show compliance through the completion of a successful static leak test on the Tokheim stage II vapor control system for pumps #1 through #8 on May 17, 2010 and a successful static leak test and dynamic pressure performance test on the Balance stage II vapor control system for the Turbo Blue pumps on June 30, 2010, however, this site failed to show compliance with the Air to Liquid ratio (A/L) testing requirements of CARB Executive Order G-70-154-AA on pumps #5 and #7 on these dates. Failing to demonstrate compliance with the A/L testing requirement is a violation of Ohio Administrative Code (OAC) rule and Montgomery County Combined General Health District Air Pollution Control Regulations (MCCGHDAPCR) section 3745-21-09 (DDD), CARB Executive Order G-70-154-AA, and Ohio Revised Code (ORC) 3704.05. On June 30, 2010, an Official Order was issued to Moraine Drive Thru to make any needed repairs and reschedule A/L testing within a thirty (30) day time period. To date, no A/L retest has been scheduled with RAPCA at this GDF.

Since the above noted GDF is currently operating in violation of OAC rule and MCCGHDAPCR section 3745-21-09 (DDD), CARB Executive Order G-70-154-AA and ORC

CONTROL AGENCY

Montgomery & Preble Counties
45422-1280
25-3486

1/12

ETA
1/12