



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Zarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 10, 2010

Nikolina Sevis  
Ohio State University  
400 Central Classroom Bldg.  
2009 Millikin Road  
Columbus, OH 43210

**Re: Construction Storm Water Inspection at Cunz Hall / Franklin County  
Permit Number: 4GC03162\*AG**

Dear Ms. Sevis:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram of Ohio EPA at Cunz Hall located at 1841 Neil Avenue in Columbus Ohio on August 27, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. During the inspection Mr. Tujalpuram talked to Mike Priday regarding the sediment and erosion controls implemented at this site. Based on the site inspection and the General Storm Water Permit, the following items were noted;

**Sediment and Erosion Controls:**

- It appears all sediment and erosion controls were in place, and are functioning as intended. Please continue to maintain all controls to ensure continued compliance with the requirements of your General Storm Water Permit.

**Maintenance:**

- This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.


**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO