



State of Ohio Environmental Protection Agency

RECEIVED ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

January 14, 2010

David McCandlish  
Agrifuels LLC  
112 South Broad Street  
Building B  
Bremen, OH 43107

**Re: Agrifuels LLC Biodiesel / Fairfield County  
Industrial Storm Water Permit 4GR00427\*DG**

Dear Mr. McCandlish:

This letter is written in regard to the storm water inspection that I conducted at Agrifuels LLC Biodiesel located at 112 South Broad Street in Bremen, Ohio. The inspection was conducted on January 12, 2010, to determine compliance with your industrial storm water permit. I did not note any discharges from your facility to a storm water drain or waters of the state.

The following items were noted during the inspection:

1. The empty drums stored outside should be closed with a lid and stored upright. Some drums were spilling product on to the ground. Please see attached picture.
2. The tanks in the rear of the building should be contained with a dike that directs the flow to the containment pond. Please see attached picture.
3. *In the future, you may consider putting a roof and containment dike at your fuel island.*

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,


Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosures

c: Jeff Bohne, DSW/CDO

GS/nsm Agrifuels LLC Biodiesel, January 12, 2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Agrifuels LLC Biodiesel  
Install dike around tanks  
Rush Creek Watershed  
January 12, 2010  
Photo by: Greg Sanders



Agrifuels LLC Biodiesel  
Place cover on drums  
Rush Creek Watershed  
January 12, 2010  
Photo by: Greg Sanders

